
100



PME Earth Terminal

Before asking the meter operator or distributor to connect the earth conductor to the PME earth terminal you should determine whether your wiring would be safe.

It is your responsibility to decide if using the provided PME earth terminal is appropriate for this property's electrical wiring installation and the intended use of the property.

If in doubt you should seek advice from a qualified electrician.

Material Code: 21758H

MATERIAL

Permanent self-adhesive film, suitably printed.

COLOUR

Background white, pictograms black (RAL 9005) and yellow (RAL 1018).

Text black.

TEXT

Helvetica Bold.

NOTE

The finished notice must not:

- (a) Lose its colour from exposure to light
- (b) Chip, crack or blister from exposure to weather

All dimensions in millimetres

Warning Sign

PME Earth Terminal

Suitability for Property's Wiring Installation

| | © UK Powe | r Networks 2012 | |
|------|-------------------|-----------------|-------|
| DRN. | RDH 29.06.12 | STANDARD | ISSUE |
| CKD. | S Tucker 01.08.12 | DRAWING NUMBER | |
| APP. | S Tucker 01.08.12 | EDS 07-0009.130 | 1 |